



**RFP #21-02 Transfer Center Roof
Addendum #1
08/02/2021**

This addendum provides clarification on project permitting and approved equals for roofing materials.

Project Permitting

The Contractor will be responsible for obtaining all required permits for this project through the City of Missoula.

Approved Equals

Polyvinyl chloride (PVC) and other thermoplastic, single-ply membranes will be accepted as approved equals to thermoplastic polyolefin (TPO) membranes for this procurement. EPDM and other thermoset membranes will not be accepted as approved equals. Non-single-ply roofing systems will not be considered.